



Quality and reliability is our tradition

KYORITSU

Digital High Voltage Insulation Testers **KEW 3125A / 3025A**

Robust & Ergonomic Design!
De Facto Standard High Voltage Insulation Testers!!



KEW 3125A

1T Ω

250V-5000V



KEW 3025A

100G Ω

250V-2500V



- **Insulation Resistance up to 1T Ω (KEW3125A)**
- **Short-Circuit Current up to 1.5mA**
- **Wide Test Voltage from 250V to 5000V (KEW3125A)**
- **Diagnosis Function of PI and DAR**
- **Newly-designed alligator clip**
- **It comes with a tough hard case**
- **Filter function reduces noise interference for obtaining stable measurement**
- **Large display with Bar Graph indication and backlight**
- **Live voltage warning**
- **Safety standard IEC61010-1 CAT IV 300V / CAT III 600V**

Made in Japan

KYORITSU ELECTRICAL INSTRUMENTS WORKS,LTD.

<http://www.kew-ltd.co.jp>

KEW3125A / KEW3025A Specifications

* 3125A only

Insulation resistance						
Rated Voltage		250V	500V	1000V	2500V	5000V*
Accuracy		0.0 - 100.0MΩ	0.0 - 99.9MΩ 80 - 1000MΩ	0.0 - 99.9MΩ 80 - 999MΩ 0.80 - 2.00GΩ	0.0 - 99.9MΩ 80 - 999MΩ 0.80 - 9.99GΩ 8.0 - 100.0GΩ	0.0 - 99.9MΩ 80 - 999MΩ 0.80 - 9.99GΩ 8.0 - 99.9GΩ 80 - 1000GΩ
		±5%rdg±3dgt	±5%rdg±3dgt	±5%rdg±3dgt	±5%rdg±3dgt	±5%rdg±3dgt ±20%rdg(100GΩ or more)
Short circuit current		1.5mA				
Output voltage	Accuracy	±10%	-10 - +20%	0 - +20%		
	Monitor	±10%rdg±20V				
Voltage measurement						
Measuring range		AC:30 - 600V (50/60Hz) DC:±30 - ±600V				
		±2%rdg±3dgt				
Power source		DC12V : LR14/R14 x 8pcs				
Applicable standards		IEC61010-1, 61010-2-030 CAT IV 300V / CAT III 600V Pollution degree2, IEC61010-031, IEC61326-1, 2-2				
Dimension		177(L) x 226(W) x 100(D) mm (Hard case 380(L) x 430(W) x 154(D) mm)				
Weight		3025A:1.7kg approx. 3125A 1.9kg approx. (including batteries) 4kg approx. (including accessories)				
Accessories		7165A(Line probe:3m), 7264(Earth cord:3m), 7265(Guard cord:3m), 8019(Hook type prod), 9180(3025A Hard Case), 9181(3125A Hard Case), LR14(Alkaline battery size C) x 8, Instruction manual				
Optional		7168A(Line probe with alligator clip:3m), 7253(Longer line probe with alligator clip:15m), 8302(Adaptor for recorder)				

Accessories



EVERYTHING YOU NEED.....

Diagnostic Insulation Tests

PI Polarization Index

PI = $\frac{\text{Insulation resistance value 10 min. after start}}{\text{Insulation resistance value 1 min. after start}}$

PI	4.0 or more	4.0-2.0	2.0-1.0	1.0 or less
Criteria	Best	Good	Warning	Bad

DAR Dielectric Absorption Ratio

DAR = $\frac{\text{Insulation resistance value 1 min. after start}}{\text{Insulation resistance value *15 sec. after start}}$

DAR	1.4 or more	1.25-1.0	1.0 or less
Criteria	Best	Good	Bad

*User-Selectable 15sec. or 30sec. interval

New alligator clip



Optional



7168A
Line probe with
alligator clip(3m)



7253
Longer line probe with
alligator clip(15m)



8302
Adaptor for recorder
(Output 1mV/1μA)

Selection Guide

MODEL	3025A NEW	3125A NEW	3126	3127	3128
Voltage range	250V/500V/1000V 2500V	250V/500V/1000V 2500V/5000V	500V/1000V 2500V/5000V	250V/500V/1000V 2500V/5000V	500V/1000V/2500V 5000V/10000V/12000V
Max measurement	100GΩ	1TΩ	1TΩ	10TΩ	35TΩ
Short circuit current	1.5mA	1.5mA	5mA	5mA	5mA
PI	✓	✓	✓	✓	✓
DAR	✓	✓	✓	✓	✓
SV/DD	—	—	—	✓	✓
Filter	✓	✓	✓	✓	✓
Capacitance	—	—	—	✓	✓
Memory/communication	—	—	—	✓	✓
Power source	LR14x8	LR14x8	LR14x8	Rechargeable lead storage Battery(12V)	Rechargeable lead storage Battery(12V)
Measurement categories	CAT IV 300V CAT III 600V	CAT IV 300V CAT III 600V	CAT III 600V	CAT IV 600V	CAT IV 600V
Dimension (mm) (L)x (W)x(D)	177x226x100	177x226x100	205x125x94	208x225x130	330x410x180



Safety Warnings :

Please read the "Safety Warnings" in the instruction manual supplied with the instrument thoroughly and completely for correct use. Failure to follow the safety rules can cause fire, trouble, electrical shock, etc. Therefore, make sure to operate the instrument on a correct power supply and voltage rating marked on each instrument.

For inquiries or orders :



**KYORITSU ELECTRICAL
INSTRUMENTS
WORKS, LTD.**

2-5-20, Nakane, Meguro-ku, Tokyo, 152-0031 Japan
Phone:+81-3-3723-0131
Fax:+81-3-3723-0152
E-mail:info-eng@kew-ltd.co.jp

<http://www.kew-ltd.co.jp>